



FIRE HYDRANT AND SPRINKLER SYSTEM RISER DIAGRAM
NTS

LEGEND	
	QUAD FEED HYDRANT
	DUAL BOOSTER CONNECTION
	DUAL BOOSTER CONNECTION
	FIRE HYDRANT
	BOOSTER PUMP
	JACKING PUMP
	FIRE SERVICES ISOLATION VALVE 2.0m MAX. ABOVE FLOOR, CHAIN 7 LOCK AS WELL AS VALVE NUMBER
	CHECK VALVE
	PRESSURE RELIEF VALVE
	MONITORED VALVES TO ACHIEVE ISOLATION REQUIRED IN AS/NZS 2419 & 2118
	SPRINKLER
	FHR FIRE HOSE REEL
	SCA SPRINKLER CONTROL ASSEMBLY
	SCV SPRINKLER CONTROL VALVE
	FIRE SERVICES PIPEWORK
	SPRINKLER PIPEWORK
	FIRE TEST DRAIN PIPEWORK

Rev.	Remark/Comment	Date:	Appr.
3	CONSTRUCTION ISSUE	23.02.22	
2	CONSTRUCTION ISSUE	05.03.21	
1	CONSTRUCTION ISSUE	03.02.21	
B	PRELIMINARY ISSUE	24.11.20	
A	PRELIMINARY ISSUE	16.10.20	

Client:
BORAT NO.3 PTY LTD

Architect:
TOM ROBERTSON ARCHITECTS



Project:
1 STEWART STREET BRUNSWICK
1 STEWART STREET
BRUNSWICK VIC 3056

Drawing:
FIRE SERVICES
SCHEMATICS

THIS DRAWING HAS BEEN DOCUMENTED IN COLOR AND MUST BE PRINTED IN COLOR, OTHERWISE INFORMATION WILL BE LOST

CONSTRUCTION

Date:	06.10.2020	Engineer:	J.B	Drawn:	I.C
Scale @ A1:	NTS	Checked:		Sheets:	9
Reference No.	133418	Drawing No.	F800	Rev.	3

© This drawing is copyright to Intrax Consulting Engineers, no part of this drawing shall be used for any other purpose without the prior written consent of Intrax Consulting Engineers.